

Indicatori de calitate – luna DECEMBRIE/2024
 Stația de epurare Negrești Oas

EVACUARE, apa uzata

-mg/l -

Data	Cod	pH	Susp.	CBO5	CCO- Cr		Extr.	Fosfor	*Deterg.	Azot	Reziduu
	Proba		totale					total		total	
1	*	*	*	*	*	*	*	*	*	*	*
2	*	6,91	5,0	*	*	22,5	*	0,678	*	5,07	*
3	P924	7,0	3,0	7,21	<30	29,82	<20(3.2)	1,2	0,28	6,9	494
4	*	7,95	6,0	*	*	*	*	*	*	6,0	*
5	*	6,83	6,0	*	*	23,2	*	0,801	*	*	*
6	*	6,87	10,0	*	*	*	*	*	*	6,3	*
7	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*
9	*	6,93	6,0	*	*	*	*	*	*	6,42	*
10	*	6,95	8,0	*	*	22,7	*	0,670	*	*	*
11	*	6,86	8,0	*	*	*	*	*	*	5,21	*
12	*	*	*	*	*	*	*	*	*	*	*
13	*	6,87	4,0	*	*	*	*	*	*	5,17	*
14	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*
16	*	6,91	6,00	*	*	*	*	*	*	5,22	*
17	*	6,95	7,00	*	*	21,8	*	0,546	*	*	*
18	*	6,90	9,00	*	*	*	*	*	*	5,57	*
19	*	6,87	7,00	*	*	22,4	*	0,558	*	*	*
20	*	7,92	7,00	*	*	*	*	*	*	5,11	*
21	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*
30	*	*	*	*	*	*	*	*	*	*	*
31	*	*	*	*	*	*	*	*	*	*	*
Media	*	7,051	6,571	7,210	*	23,737	3,200	0,742	0,280	5,697	494,000
CMA	*	6.5-8.5	35,00	25,00	*	125,00	20,00	2,00	0,50	15,00	2000,0

Încercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator