

Evacuare, apa uzata, mg/l

Data	Cod	pH	Suspensii	CBO5	CCOCr	Extr.	Amoniu	Fosf.	*Deterg.	Azot	Reziduu	*Fier	*Mangan	*Zinc	*Cupru
	proba							total		total		total			
1	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
2	P919	7,4	8,00	*	*	*	0,317	0,381	*	7,60	*	*	*	*	*
3	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
4	P926	7,6	8,00	8,72	35,23	*	0,444	0,363	*	6,46	*	*	*	*	*
5	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
6	P938	7,7	7,00	8,72	35,14	*	0,506	0,381	*	7,27	*	*	*	*	*
7	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
8	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
9	P943	7,8	6,00	*	*	*	0,651	0,396	*	6,90	*	*	*	*	*
10	P947	7,5	7,00	8,70	32,80	<20(5.6)	*	0,680	0,32	7,20	458,00	<0.2(0.001)	<0.005(0.001)	<0.02(0.001)	<0.01(0.001)
11	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
12	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
13	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
14	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
15	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
16	P973	7,4	7,00	*	*	*	0,602	0,440	*	6,80	*	*	*	*	*
17	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
18	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
19	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
20	P990	7,5	5,00	*	*	*	0,742	0,550	*	8,31	*	*	*	*	*
21	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
22	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
23	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
24	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
25	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
26	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
27	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
28	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
29	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
30	P994	7,4	9,00	*	*	*	0,406	0,48	*	7,97	*	*	*	*	*
31	P996	7,3	5,00	*	*	*	0,583	0,56	*	8,67	*	*	*	*	*
Media	*	7,51	6,89	8,71	34,39	5,60	0,531	0,47	0,32	7,46	458,00	0,001	0,001	0,001	0,001

*Incercările marcate cu * sau hasurate NU sunt acoperite de acreditarea RENAR*

Rezultatele notate cu "<" reprezintă valorile situate sub limita de determinare a metodei

Prezenta raportare este doar pentru uzul intern

Întocmit
Responsabil calitate

Avizat
Responsabil laborator